



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: +32 (0)2 264 03 60
Fax: +32 (0)2 268 89 58
www.apragaz.com
info@apragaz.com



084 - PROD
17065

NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE

In accordance with module B of the Marine
Equipment Directive 2014/90/EU as amended

Certificate N°
03/IT/531-4-REV 0

Manufacturer

Name

ANAF FIRE PROTECTION S.P.A.

Address

Via del Commercio, 4
IT - 27020 Torre d'Isola (Pavia)
ITALY

Concerned Equipment: Portable Fire Extinguishers (Powder or Water Based Stored Pressure)

Type: a) PS2-Y ABC according to technical design ref. 33.250 B.F000.00
b) PS2-YN ABC according to technical design ref. 33.254 B.F000.00
c) PS2-P ABC according to technical design ref. 33.259 B.F000.00
d) FS2-Y according to technical design ref. 09.250 B.F000.00
e) FS2-P according to technical design ref. 09.259 B.F000.00

Capacities: 2 kg/l

Set pressure: max. 13,98 bar (+60°C)

Test pressure: PT = 20 bar

Service temperature range: min. -30°C / max. +60°C for a) b) c)
min. 0°C / max. + 60°C for type d) e)

Used Standards : EN3.7:2004 A1:2007 & EN3.8:2021

The manufacturer is allowed to affix the marine CE mark  (followed by NOBO n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive, only if the requirements stated in module D are fully complied with

The approval is valid until 05/02/2027

APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the types of these pressure vessels conform with the relevant requirements of the pertinent EN 3-7; EN 3-8 standards and the Marine Equipment Directive 2014/90/EU on bases of the documentation and samples supplied for review and approval.

Date : 02/05/2023

Name : B.Nève, Ir.

Position **General Manager**

Notified body identification number :

0029

Signature

Notified body stamp :

APRAGAZ VZW / ASBL

Notified body reference :

P4434/000